



CERTIFICATE OF CONFORMITY

Date:		Customer:	
Order No:		Quantity	

This is to certify that the range of 1060A PN25 Check Valve range is manufactured in accordance with ISO 9001-2000 Quality Management Systems & are designed in line with the BS 5154 - Series B standard.

Sizes 1/2" to 3" have been classified as S.E.P. (Sound Engineering Practice) under the scope of the European Pressure Directive (97/23/EC) and as such cannot therefore be CE marked.

MATERIALS

Body	BSEN 1982 CC491K	Valve	BSEN 1982 CC491K
Cap - 1/4" to 2"	BSEN12165 CC617N	Swinger - 1/4" to 1"	BSEN12164 CW617N
Cap - 2.1/2" to 4"	BSEN 1982 CC491K	Swinger - 1.1/4" to 4"	BSEN 1982 CC491K
Pin Cap	BSEN12164 CW617N	Nut	BSEN12164 CW617N

BODY ENDS

ISO 7 (BS21), ISO 228 (BS2779) ANSI (NPT)


TEST PRESSURES (Hydrostatic)

Body - 37.5Bar (544 psi)

Seat - 27.5Bar (400 psi)

AGREED CONCESSIONS

Certified that the supplies detailed hereon have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below conform in all respects to the specifications / drawing(s) relevant thereto.



S.M. Holloway
Quality Manager

SALES OFFICES

Pegler Northern: Tel: 0870 1200281 Fax: 01302 560108
Pegler Southern: Tel: 0870 1200282 Fax: 01302 560458
Pegler Western: Tel: 0870 1200283 Fax: 01302 560109

Registered Office: St Catherine's Avenue, Doncaster, DN4 8DF Reg. No. 1194543